

VNIV.EX15242 - Sprinklers, Automatic and Open

Sprinklers, Automatic and Open

[See General Information for Sprinklers, Automatic and Open](#)

NEWAGE FIRE PROTECTION INDUSTRIES PVT LTD

EX15242

4, Champaklal Udyong Bhavan, Sion E
Mumbai, Maharashtra 400022 INDIA

Sprinkler Identification Numbers (SIN), Glass Bulb Type NI012, NI022, NI032, NI042, NI052, NI062, NI072, NI082, NI012 D, NI 022 D, NISRHO3, NIQRH03, NI SR P02, NI QR U02, NI QR P02, NI310, NI311, NI320, NI321, NI340, NI341

Sprinkler Identification Numbers (SIN), Glass Bulb Type NI-SP10, NI-QP10, NI-SU10, NI-QU10, NI-SC10, NI-SH10, NI-QH10.

Sprinkler Identification Number (SIN) NI020, NI030, NI075, NI085, NI070, NI080, Glass Bulb Type.

Chrome plated brass sprinklers are identified by unplated loading screws.

UPRIGHT AND PENDENT STANDARD SPRAY SPRINKLERS NOMINAL 5.6 K-FACTOR

SIN	Response Type	Type	Nom K-Factor	System Working Pressure, psig	Temp Rating, °F
NI032	SR	Upright	5.6	175	135, 155, 175, 200
NI042	QR	Upright	5.6	175	135, 155, 175, 200
NI052	SR	Pendent	5.6	175	135, 155, 175, 200
NI062	QR	Pendent	5.6	175	135, 155, 175, 200
NI SR P02	SR	Pendent	5.6	175	155, 175
NI QR P02	QR	Pendent	5.6	175	155, 175
NI SR U 02	SR	Upright	5.6	175	155, 175
NI QR U02	QR	Upright	5.6	175	155, 175
NI310	SR	Upright	5.6	175	135, 155, 175, 200, 286
NI311	QR	Upright	5.6	175	135, 155, 175, 200, 286
NI320	SR	Pendent	5.6	175	135, 155, 175, 200, 286
NI321	QR	Pendent	5.6	175	135, 155, 175, 200, 286
NI-SP10	SR	Pendent	5.6	175	155, 175
NI-QP10	QR	Pendent	5.6	175	155, 175
NI-SU10	SR	Upright	5.6	175	155, 175
NI-QU10	QR	Upright	5.6	175	155, 175
NI075	SR	Upright	5.6	175	135, 155, 175

NI085	QR	Upright	5.6	175	155
NI070	SR	Pendent	5.6	175	135, 155, 175
NI080	QR	Pendent	5.6	175	155

STANDARD SIDEWALL SPRAY SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	System Working Pressure, psig	Temp Rating, °F
NI012+#	SR	Horizontal	5.6	175	135, 155, 175, 200
NI022+#	QR	Horizontal	5.6	175	135, 155, 175, 200
NI012 D*#	SR	Horizontal	5.6	175	135, 155, 175, 200
NI022 D*#	QR	Horizontal	5.6	175	135, 155, 175, 200
NISRHO3+#	SR	Horizontal	5.6	175	135, 155, 175, 200
NIQRHO3+#	QR	Horizontal	5.6	175	135, 155, 175, 200
NI340	SR	Horizontal	5.6	175	135, 155, 175, 200, 286
NI341	QR	Horizontal	5.6	175	135, 155, 175, 200, 286
NI-SH10#+	SR	Horizontal	5.6	175	155,175
NI-QH10#+	QR	Horizontal	5.6	175	155,175
NI020+#	SR	Horizontal	5.6	175	155
NI030+#	QR	Horizontal	5.6	175	155

+ Installed 4 to 12 in. below ceiling.

* Installed 4 to 6 in. below ceiling.

For ordinary hazard occupancies.

FLUSH, RECESSED, AND CONCEALED SPRINKLERS

SIN	Response Type	Type	Nom K-Factor	Cover	Temp Rating °F Sprinkler
NI072	SR	Concealed	5.6	135, 155	135, 155, 175, 200
NI082	QR	Concealed	5.6	135, 155	135, 155, 175, 200
NI SR P02	SR	Recessed Pendent	5.6	—	155, 175
NI QR P02	QR	Recessed Pendent	5.6	—	155, 175

CONVENTIONAL (OLD STYLE) SPRINKLERS

SIN	Response Type	Nom K-Factor	Temp Rating, °F
NI-SC10	SR	5.6	155, 175

Trademark and/or Tradename:  NewAgeNI ^{NEWAGE} Plus⁺
Innovative Fire Solutions

Last Updated on 2019-08-08

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"