



# VUFZ.EX15879 - Nozzles, Spray Hose, Portable

## Nozzles, Spray Hose, Portable

[See General Information for Nozzles, Spray Hose, Portable](#)

**NEWAGE FIRE PROTECTION INDUSTRIES PVT LTD**

EX15879

4, Champaklal Udyong Bhavan, Sion E  
Mumbai, Maharashtra 400022 INDIA

### Constant/Select Flow (Gallage) Spray Nozzles

Model No.	Fire Type	Size, in.	Max Inlet Pressure, psig	Rated Operating Pressure, psig	Selectable Flow at Rated Operating Pressure, gpm
<b>Constant/Select flow (gallage) spray nozzle</b>					
Superfire Junior	Class A and B	1-1/2*	175	100	30 59 93 125

For model Superfire Junior - \*Includes NH (NST) inlet thread configurations. Also includes BS 336 "Morris" instantaneous coupling inlet configuration.

### Basic Spray Nozzles

Model No.	Fire Type	Size, in.	Max Inlet Pressure, psig	Rated Operating Pressure, psig	Rated Flow at Rated Operating Pressure, gpm	Flow in Wide Open Position at 100 psig, gpm
<b>Basic spray nozzle</b>						
NewAge SNZL - 2.1/2	Class A and B	2-1/2*	200	100	280	280
NewAge SNZL - 1.1/2	Class A and B	1-1/2**	200	100	130	130

For model NewAge SNZL - 2.1/2 - \*Includes both NH (NST) and NPSH (IPT) inlet thread configurations. Also includes BS 336 "Morris" instantaneous coupling inlet configuration.

For model NewAge SNZL - 1.1/2 - \*\*Includes both NH (NST) and NPSH (IPT) inlet thread configurations.

Use of solid stream from nozzle around live electrical apparatus and circuits may involve serious accident hazard and these nozzles, therefore, are not recommended for Class C fires.

Trademark and/or Tradename: "SUPERFIRE JUNIOR", NewAge

Last Updated on 2019-05-20

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"